



Karnataka State Fire & Emergency Services

Office of the District Fire Officer

Sarjapura-Road Fire Station, Bengaluru-560035.

Ph : 080-25746166



C.NO: 36/DFO/SRFS/FSCR/2024

dt: 02-09-2024

"Annexure--2"
Educational Buildings

To,
The Authorized Signatory
M/s. Global Indian International School,
Sy.No:5,6,8, Heggondanahalli village,
Whitefield – Sarjapura main road,
Gunjur post, Bangalore – 560 087.

Sir,

Sub: Issue of **"Fire Safety Compliance Certificate"** with respect to fire prevention, fighting and Evacuation measures maintained at **"M/s. Global Indian International School, Sy.No.5,6,8, Heggondanahalli village, Whitefield – Sarjapura main road, Gunjur post, Bangalore – 560 087."**

- Ref: 1) DFO office FSR No: 36/DFO/SRFS/Bng/FSR/2024. Dt:-02-09-2024.
2) Your request letter dated: 14-06-2024.
3) FSO Inspection report no.35/FSO/SRFS/BNG/2024. Dt:-22/06/2024.

<<<>>>

With reference to the above cited subject, as per reference (1) a conditional Fire Safety Recommendation was issued to the premises of "M/s. Global Indian International School, Sy.No.5,6,8, Heggondanahalli village, Whitefield – Sarjapura main road, Gunjur post, Bangalore – 560 087." with a Condition to fulfill the recommendations and compliance the same within 03 months,


With reference cited (2) above, the management of **"M/s. Global Indian International School"** had requested for Issue of fire safety compliance report from our department. In this regard the Fire Station officer, Sarjapura road Fire Station, Bangalore was inspected the building on **dt: 19-06-2024** and submitted the report recommending to Issue the fire safety Compliance Certificate.

Under the above circumstance the Karnataka Fire & Emergency Services Department is Issuing the **"Fire Safety Compliance Certificate"** to **"M/s. Global Indian International School, Sy.No.5,6,8, Heggondanahalli village, Whitefield – Sarjapura main road, Gunjur post, Bangalore – 560 087."** Subject to proper maintenance of fire fighting installations in the good working conditions and arrange for 40% of staffs/ employees are training within 03 months from the date of issue of this Certificate.

"This Certificate is valid for two years from the date of issue and is renewable without fail'.



Yours faithfully,


DISTRICT FIRE OFFICER
Sarjapura Road Fire Station
Bengaluru-560035



Karnataka State Fire & Emergency Services

Office of the District Fire Officer

Sarjapura-Road Fire Station, Bengaluru-560035.

Ph: 080-25746166



C.NO: 36/DFO/SRFS/FSR/2024

dt: 02-09-2024

"Annexure--2"

Educational Buildings

To,
The Authorized Signatory.
M/s. Global Indian International School,
Sy.No.5,6,8, Heggondanahalli village,
Whitefield – Sarjapura main road,
Gunjur post, Bangalore – 560 087

Sir,

Sub: Issue of "Fire safety Recommendation Certificate" to "M/s. Global Indian International School, Sy.No.5,6,8, Heggondanahalli village, Whitefield – Sarjapura main road, Gunjur post, Bangalore – 560 087."

Ref: 1) Your Request letter Date: 14/06/2024:

2) FSO Inspection report no.35/FSO/SRFS/BNG/2024. Dt: 22/06/2024.

<<<<<>>>>

With reference to the subject cited above, the premises "M/s. Global Indian International School, Sy.No.5,6,8, Heggondanahalli village, Whitefield – Sarjapura main road, Gunjur post, Bangalore – 560 087." was inspected by Fire Station officer Sarjapura-road fire station, Bangalore on **Dt:19-06-2024** for suggesting fire prevention, fire fighting & evacuation measures. The details are as follows:-

A. Details of the building / premises :-


01	Name and Address of the Applicant.	:	The Authorized Signatory. M/s. Global Indian International School, Sy.No.5,6,8, Heggondanahalli village, Whitefield – Sarjapura main road, Gunjur post, Bangalore – 560 087.
02	Name and Address of the premises.	:	M/s. Global Indian International School, Sy.No.5,6,8, Heggondanahalli village, Whitefield – Sarjapura main road, Gunjur post, Bangalore – 560 087.
03	Name and address of the Building owner	:	M/s. Global Indian International School, Sy.No.5,6,8, Heggondanahalli village, Whitefield – Sarjapura main road, Gunjur post, Bangalore – 560 087.
04	Number of buildings	:	Two Buildings
05	Number of floors	:	Block-1, Ground + 2 upper floors. Block-2, Ground + 2 upper floors.



06	Floor-wise details of occupancy:-	
	Block-1	
	Ground floor	: 14 Class rooms, Pre Primary block-1. 01 staff room and 01 Admin block.
	1 st floor	: 19 class rooms 01 Science lab, 01 laboratory & Auditorium.
	2 nd floor	: 19 class rooms 01 Science lab, 01 laboratory & Auditorium.
	Block-2	
	Ground floor	: 11 Class rooms and 01 Computer lab.
	1 st floor	: 11 class rooms.
	2 nd floor	: 11 class rooms.
07	Height of the building	: Block-01 : 11.20 Mtrs. Block -02 : 11.80 Mtrs.
08	Site area	: 17,907.09 Sq Mtrs.
09.	Built-up area of each floor:-	
	Block-1	
	Ground floor	: 2,391.08 Sq. Mtrs.
	1 st floor	: 2,478.24 Sq. Mtrs.
	2 nd floor	: 2,478.24 Sq Mtrs.
	Block-2	
	Ground floor	: 2,391.08 Sq. Mtrs.
	1 st floor	: 2,478.24 Sq. Mtrs.
	2 nd floor	: 2,478.24 Sq Mtrs.
10.	Total built-up area	: 14,695.12 Sq. Mtrs.
11.	Surrounding properties:-	
	East (Front)	: School play ground.
	West (Rear)	: 15.00 mtrs wide Varthur -Sarjapura main road.
	North (side)	: School building
	South (side)	: Vacant land
12.	Set-back area available around the building :-	
	East (Front)	: Minimum 04.80 mtrs
	West (Rear)	: 04.00 mtrs
	North (side)	: Minimum 10.00 mtrs
	South (side)	: 04.80 mtrs.

B. On inspection of this Industrial premises, the following fire prevention, fire fighting and evacuation measures recommended are considered absolutely essential from fire safety point of view :-

Sl. No. (1)	Details (02)	Existing (03)	Recommendations (04)
01.	Accessibility to the premises	The premise is accessible from 15.00 Mtrs wide Varthur-Sarjapura main road located on western side the road is hardened to carry the Weight of 45.000 Kgs.	Adequate
02.	No. of entrances	02 entrance/exit	Complied
03.	Width of entry / exit	Each entrance/exit of 06.20 mtrs has been provided.	Adequate



04.	Diesel generators.	Two no's of Standby Generators each of 65KVA capacity has to be provided and connected to all emergency fire fighting & lighting systems.	Complied.
05.	No. of staircases available	Nos. of staircases : 03	Complied
		Width of staircases : 1.90 mtrs 1.60 mtrs 1.60 mtrs	
		Width of treads : Each of 35 cm	
		Height of risers : Each of 15 cm	
		Nos. of riser per flight : Each of 12	
		Height of handrails : Each of 1.10 mtrs	
		Head room clearance : Each of 2.20 mtrs	
06.	No. lifts and capacity.	Not Provided	Complied
07.	Fire extinguisher	25 no's of ABC fire extinguishers, each Of 06 kg capacity & 05 No. of Co2 fire extinguishers of 4.5kg capacity has been provided in each floor of the both Buildings.	Complied
08.	First aid Hose reel hose.	02 no's of Hose Reel Hose has been provided of 19 mm size of adequate length to reach the farthest point of floor has been provided with shut off branch having a nozzle of 5mm size. have been provided in each buildings.	Complied
09.	Terrace tank over respective tower terrace.	10,000 liters capacity of terrace tank has been provided for each system.	Complied
10.	At the terrace tank level with minimum pressure of 3.5kg/cm ² .	A booster pump has been installed at the terrace level capable of delivering 900 liters of water per minute.	Complied
11.	Escape routes	Escape routes have been marked in which visibly to guide the students make to safer Places.	Complied
12.	No Smoking Board	No smoking board has been displayed in English and kannada at inside the entry/exit of the each floor.	Complied
13.	Fire Siren	A Fire siren has been installed inside the premises to inform all the inmates in case of a fire emergency and evacuate the area.	Complied
14.	Nominate one fire no Nodal Officer	One Non-teaching staff Mr.guruprasad has been nominated as fire nodal officer for the school premises.	Complied
15.	Fire order	A notice board has been displayed the Action to be taken by the school staffs in	Complied



		Case of an emergency with Telephone Numbers of Sarjapura Road Fire Station i.e. 25746166 & 101 and telephone numbers of nearest Ambulance Service & Management Has been displayed.	
16.	Fire fighting training	Not trained	The staff or employees Should be got trained in fire prevention And fire fighting evacuation measures at R.A.Mundkur Fire & Emergency Services Academy, B.G.Road, Bangalore-29
17.	<p>General Fire precaution measures :-</p> <p>A. Explosive and flammable materials should not be stored in the store room, UPS room, Electrical panel area, class rooms, laboratory & electrical sum panel premises.</p> <p>B. Accumulation of combustibile waste in and around the premises should be avoided.</p> <p>C. The exit ways shall be always kept clear without any obstruction.</p> <p>D. Liquefied petroleum gas should be not stored in the building.</p> <p>E. The doors shall not be kept locked/latched during working hours and shall be free from obstruction.</p> <p>F. During the class hours the class room doors shall not be locked from inside to outside.</p> <p>G. As per Hon'ble Supreme Court order all teacher and staff shall be trained to handle safety equipment, initiate emergency evacuation and protect their students in the event of fire and other emergency and the school shall observe the Fire Safety day on April 14th of every year by conducting fire safety drills with co-ordinate with Fire Service Department.</p> <p>H. This Fire Safety Recommendation is issued from the fire prevention, fire fighting and evacuation measures. Karnataka State Fire & Emergency Services Department is not responsible for the ownership of the land, its location and other disputes, which may arise in due course.</p>		

Under the above circumstance, the Karnataka Fire & Emergency Services Department is issuing "Fire Safety Recommendation" to "M/s. Global Indian International School, Sy.No.5,6,8, Heggondanahalli village, Whitefield – Sarjapura main road, Gunjur post, Bangalore – 560 087." subject to condition and compliance of the above recommendations as shown in Column-4 of Part-B within 03 months and compliance from the undersigned.

"This Fire Safety Recommendation is valid for Two Years from the date of issue and it is renewable."

Yours faithfully,


DISTRICT FIRE OFFICER
Sarjapura Road Fire Station
Bengaluru-560035